

**Date:** 12-18-2020

**To:** All Plan Holders

**Subject:** ADDENDUM NO. 4

**Project:** CENTER FOR MATERIALS AND MANUFACTURING SCIENCES, TROY UNIVERSITY MAIN CAMPUS-TROY ALABAMA

**Job #:** SSL# 18144  
BC# 2020416  
PSCA#: 006P



**From:** Cody Smith

The plans dated November 17, 2020 and Specifications dated November 2020 of the subject project, and any subsequent addenda are amended as follows: (Where there are conflicts between the plans and specifications and the addendum, this addendum shall govern)

**Item 1:** Refer to the Specifications ADVERTISEMENT FOR BIDS. **Delete** the first paragraph and **Replace** with the following:

The date sealed proposals for both base bid and alternates will be received by Troy University is postponed until further notice.

**Item 2:** Refer to Specification Section 26 0000 18.26, Docking Station:

- Change enclosure in paragraph 18.26.10 to be Type 3R stainless steel.

**Item 3:** Refer to Specification Section 26 0000 18.26, Docking Station:

- Change cam-style connectors in paragraph 18.26.11 to be rated 800 amps.

**Item 4:** Refer to Specification Section 26 0000 18.26, Docking Station:

- Change circuit breakers in paragraph 18.26.13 to be 4-pole and rated 800 amps.

**End of Addendum No. 4**