

**Date:** 02-22-2021

**To:** All Plan Holders

**Subject:** ADDENDUM NO. 8

**Project:** CENTER FOR MATERIALS AND MANUFACTURING  
SCIENCES, TROY UNIVERSITY MAIN CAMPUS-TROY ALABAMA

**Job #:** SSL# 18144  
BC# 2020416  
PSCA#: 006P



**From:** Cody Smith

The plans dated November 17, 2020 and Specifications dated November 2020 of the subject project, and any subsequent addenda are amended as follows: (Where there are conflicts between the plans and specifications and the addendum, this addendum shall govern)

**Item 1:** Refer to the Specifications ADVERTISEMENT FOR BIDS. **Delete** the first paragraph and **Replace** with the following:

Sealed proposals will be received by Troy University by the Purchasing Department of Troy University, at the Physical Plant Conference Room, located at 1 melton Carter Dr, Troy, Alabama 36081 until 2:00 PM CST for the base bids and 3:00 PM CST for all alternates on Thursday, February 25, 2021 at which time they will be open and read.

**Item 2:** Refer to the drawings, Sheet M4.4, Energy Recovery Unit (Run Around Coil) Schedule (ERU-1) and make the following change:

Fan motors shall be 50HP each in lieu of the originally specified 40HP.

**Item 3:** Refer to Sheet E023, Panelboard Schedule: In Panel 3HEQ, change the three 90A/3P breakers serving Exhaust Fans to 100A/3P.

**End of Addendum No. 8**